



LEGEND

- ☆ The maximum depth to the inspection pipe may be varied only if there is insufficient cover to serve the block
- Length of short pipe shall be 400mm.
- * Concrete Surround Inspection Opening (point of responsibility)

NOTES:

1. Concrete (excluding access chambers) N20 in accordance with AS 1379 and AS 3600
2. Pipe materials and fittings shall have a 'Standards Mark' under the National Plumbing Certification Scheme.
3. Where rigid pipes are used in sewers a 500 long pipe shall be located on each side of the house connection branch.
4. All dimensions in millimetres.

REVISIONS	DATE
D DEVELOPMENT MANUAL UPDATES AND AMENDMENTS 2018	26/10/18
C GENERAL UPDATES AND STANDARD REFERENCING AMENDMENTS	6/5/16
B MINOR AMENDMENTS	10/3/98
A ORIGINAL ISSUE	1/3/97



Whitsunday
Regional Council

Email: info@whitsundayrc.qld.gov.au Web: www.whitsundayrc.qld.gov.au

BOWEN
67 Herbert St
Bowen 4805 Q
Ph 07 4761 3600

COLLINSVILLE
Cnr Stanley & Conway Sts
Collinsville 4804 Q
Ph 07 4785 5366

PROSERPINE
83-85 Main St
Proserpine 4800 Q
Ph 07 4945 0200

HOUSE CONNECTION TYPES

SEWERAGE
Standard
Drawing
S-0030

A B C D